

CEMB S.p.A. Costruzioni Elettro Meccaniche ing. BUZZI & C. SpA

sede legale: Via Risorgimento, 9 - 23826 Mandello del Lario (Lc) Italy tel +39 0341 706111 - cemb@cemb.com - www.cemb.com

Industry balancing divisionfax+390341735678Garage equipment divisionfax+390341700725Vibration analysis divisionfax+390341706299



SAFETY INSTRUCTIONS

VIBRATIONS TRANSDUCER - MODEL T-NC/8-API

Document No. I56PRD of 12/03/19 rev. 03

protocollo
B9007082

allegato al certificato
CESI 03 ATEX 094 X

09/04/2019

Contents:

10 pages

Page 1 Page 2 Page 4	Product specifications Limits of use – ATEX marking Device suitability for the place of installation Installation
Page 6	Testing and maintenance Repair
Page 7	Marking drawing no. 04PT029296
Page 8	Warning label drawing no. 04PT002870
Page 9	Warning label drawing no. 04PT002871
Page 10	Installation drawing no. 87SE002022

1. Product specifications



The T-NC/8-API converter, together with ST-NC/8 sensor and CPT-NC/8 cable, measures the relative vibrations or axial displacement of a shaft with respect to a support. The output is a negative voltage value proportional to the target distance.

Electrical characteristics

Nominal voltage -24 V Nominal current 10mA

Ambient conditions

Converter temperature -30 ÷ +80°C Cable/Sensor temperature -55 ÷ +175°C Converter relative humidity 95% non condensing Cable/Sensor relative humidity 100% Sensor degree of protection IP67

2. Limits of use - ATEX marking

Introduction

The safety measures and equipment used in the place of installation, operation and maintenance must follow the specific instructions contained in this manual and the applicable installation regulations (basic regulations of the place of installation) and the additional regulations for places with an explosive gas atmosphere in accordance with EN 60079-14 and EN 60079-17 as regards installation and testing as well as EN 60079-19 as regards maintenance and repair (unless otherwise specified).

These safety instructions refer to installation, use and maintenance of the T-NC/8-API converter, ST-NC/8 sensor and CPT-NC/8 cable. The devices have been designed and constructed according to EN 60079-0, EN 60079-11 and rules and according to 2014/34/UE directive (ATEX).

These instructions are intended for suitably trained and informed installers and users that already have basic technical experience in installation and use of electrical systems and machinery in places where there is a risk of explosion.

ATEX marking of T-NC/8-API

The device described in these instructions is characterised by the following protection level:

II 1G Ex ia IIC T6 / T5 Ga $Ta = -30^{\circ}C - +60 / +80^{\circ}C$

Sensor ST-NC/8 and cable CPT-NC/8 have operating temperature from -55°C up to +175°C. The temperature classification depends of the machine temperature on which the product is fitted: T6 up to +60°C; T5 up to +80°C; T4 up to +110°C; T3 up to +175°C

These safety instructions as well as the warnings indicated in the user manual provided to the customer must be observed.

If the T-NC/8-API device is installed in Zone 0, it needs to be enclosed in a stainless steel container or in any case according to the regulations for use in Zone 0 in order to prevent possible charge accumulation.

The installer and user are always responsible for ensuring that the characteristics of the places of installation are in accordance with the above mentioned limits and specifications.

Drawing no. 04PT029296 shows the identification data plate. Drawing nos. 04PT002870 and 04PT002871 show the warning labels.

Doc. no. I56PRD of 12/03/19 rev.3

Legend of safety-related data indicated on the identification data plate

11	Environments other than mines
1G	Zone 0 for GAS
Ex ia	Class "ia" equipment
II C	Group IIC equipment suitable for Group IIC substances (gas)
T6-T5	Temperature class T6 (85°C); T5 (100°C)
CE	Mark of conformity to European directives applicable
€x>	Marking of conformity according to directive 2014/34/UE and the relevant technical regulations
CESI 03 ATEX 094	Laboratory name that issued the CE type certificate; 03 = year of first issue of the certificate; 094 = number of the certificate.
0722	Number of the Notified Body (CESI) that performs surveillance of the production system
CESI	Name of the laboratory that issued the certificate and the certificate number
Tamb	Ambient temperature: -30 to +60°C T6 -30 to +80°C T5
Ga	EPL (equipment protection level)

Notes:

a)

Group IIC equipment is also suitable for group IIB and IIA. The intrinsic safety device to be interfaced must be chosen based on the output parameters of the b) associated device.

3. Device suitability for the place of installation

If used in areas where there is a risk of explosion, it must be verified that the type of device identified is suitable for the area classification and for flammable substances in the system. The essential safety requirements against the risk of explosion in the classified areas are laid down by the European Directives 2014/34/UE of 26 February 2014 (as regards equipment) and 1999/92/EC of 16 December 1999 (as regards systems). The criteria for classification of areas with a risk of explosion are specified in EN 60079-10. The technical requirements for electric systems in the classified areas are specified in EN 60079-14.

The measurement chain, composed of converter, sensor and cable, must be installed in zone 0 or 1 and interfaced with suitable barriers compatible with the power supply (terminals 1 - 2) and signal output (terminals 2 - 3).

As well as the functional data, also the references to the notified certification bodies are indicated on the data plate.

4. Installation

Fitting

The T-NC/8-API converter must be connected to a sensor type CT-NC/8 by means of a dedicated extension cable CPT-NC/8.

For details on mechanical installation and sensor positioning, refer to the instruction manual.

The T-NC/8-API, shall be mounted within a suitable enclosure, to prevent ingress of moisture or dust or by access to conducting parts and in order to protect against unauthorized interference and damage, the components and internal wiring of the equipment.

When the equipment is installed in Zone 0, shall be placed inside a stainless steel housing

Electrical connection and coordination

The electrical connection must be carried out by appropriately trained persons following the indications in the drawing no. 87SE002022.

The electrical connections regard:

- Tripolar shielded power/signal cable (TERMINALS 1-2-3).
- Connection to CEMB sensor model ST-NC/8 API (TERMINAL 4) directly or using CEMB cable model CPT-NC/8

The device input/output parameters are defined in the table below and indicated in the marking.

	TERMINALS	PARA	AMETERS
		Max terminals 1-2-3	
		Ui = 28 V	Ui = 26.6 V
Power supply	1 – 2	li = 120 mA	li = 135 mA
Output	2 – 3	Pi = 840 mW	Pi = 900 mW
		Ci = 30nF	
		Li = 200uH	
			General parameters
		CEMB	Uo = 28 V
Sensor connection	4	sensor model ennection ST-NC/8	Io = 120 mA
(miniature threaded coaxial connector)		Cable model CPT-NC/8	Po = 840 W
ooimootoi,			Co = 2nF
			Lo = 90uH
			$Lo/Ro = 40uH/\Omega$

CEMB sensor model ST-NC/8 parameter are:

Ui=28V - Ii=120mA - Pi=840mW - Ci=1nF* - Li=80uH

CEMB cable model CPT-NC/8 parameter are:

Ui=28V - Ii=120mA - Pi=840mW - Ci=1nF* - Li=negligible

WARNING:

- The cable must not be shortened or lengthened as it would result in a measurement error.
- The intrinsic safety circuits must be powered by associated devices that comply with the above mentioned electrical specifications.
- Do not mount or connect with very low ambient temperature (recommended temperature not below -5°C)

Experts must assess whether the system composed of the associated device, the intrinsic safety device and the connection cables is in accordance with the EN 60097-14 requirements.

^{*}Cable total length max. 12m

5. Testing and maintenance


Device testing and maintenance must be carried out according to the criteria specified in EN 60079-17.

6. Repair

In the event of malfunctioning or damage, it is advisable to send the device to CEMB S.p.A. for repair.

If repairs are not carried out by the manufacturer, they must be carried out according to the criteria specified in EN 60079-19 at workshops equipped with the necessary tools for repair and subsequent testing, and who have adequate technical knowledge also relating to the protection levels.

Doc. no. I56PRD of 12/03/19 rev.3



Cod:

Rev.

30 120 400 2000 ±0.1 ±0.15 ±0.2 ±0.5

TOLLERANZE ANGOLARI: 1 30" TOLL. 10.05 SMUSSI NON OUOTATE 0.5x45° A 6

19/02/2019 Alippi A

Disegnatore:

Data:

Clente: Ordine

RAGGI NON QUOTATI: 1 MAX DA 0.5 7 31 121 401

TOLLERANZE ISO 2768-fH

NOTE

Ra 3.2/ CEMB Ing. Buzzi & C. - S.p.A. Costruzioni Elettro Meccaniche

SCALE	7:,1	יישט מן ייימררייייים.	
FOGLIO	1 d 1	Disegno:	
FORMATO	A4	Descrizione:	ATEX MARKING

